

Fly-ash Generation & Utilization Report for Feb, 2023 of M/S GVK Power (Goindwal Sahib) Ltd, Goindwal Sahib

TPP & installed capacity	Coal cons. in MT	Ash %	Ash Generated MT			Utilization						Data of period available				
			DFA (Dried Fly Ash)	Bottom Ash	Total	DFA			Pond ash				Total Ash utilized	DFA %	Total ash %	
						Cement	Brick mfg.	Others	Total	Cement	Others					Total
GVK Goindwal Sahib Power Plant (2x270)	180172.1	33.45	54240.82	6026.76	60267.58	26936.8	11106.33	2925.795	40968.93	0	18988.80	18988.8	59957.73	75.53	99.49	01/02/2023 28/02/2023
Grand Total	180172.1	33.45	54240.82	6026.76	60267.58	26936.8	11106.33	2925.795	40968.93	0	18988.80	18988.8	59957.73	75.53	99.49	
Generation of units (MWh)	PLF	Water consumption for slurry discharge	Waste Water Generation Monthly (m3)													
266597	73.47	140508	0													

Date: 06.03.2023



[Handwritten signature]